

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/02/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155479		(X2) MULTIPLE CONSTRUCTION A. BUILDING 04 B. WING _____		(X3) DATE SURVEY COMPLETED 09/27/2012	
NAME OF PROVIDER OR SUPPLIER KINGSTON CARE CENTER OF FORT WAYNE				STREET ADDRESS, CITY, STATE, ZIP CODE 1010 W WASHINGTON CENTER RD FORT WAYNE, IN 46825			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Environmental Preoccupancy Survey for the relocation of beds to the new 300 hall rooms 301 through 312 and a Quality Assurance Walk-thru Survey were conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 09/27/12</p> <p>Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this Life Safety Code, Environmental Preoccupancy and Quality Assurance Walk-thru survey, Kingston Care Center of Fort Wayne was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety From Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and with 410 IAC 16.2-3.1-19, Environment and Physical Standards of the Indiana Health Facilities Rules for Comprehensive care facilities for the new 300 hall.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, areas open to the corridors and hard wired smoke detectors in 92 resident rooms and battery operated smoke detectors in 28 resident rooms. The facility has a</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/02/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155479		(X2) MULTIPLE CONSTRUCTION A. BUILDING 04 B. WING _____		(X3) DATE SURVEY COMPLETED 09/27/2012	
NAME OF PROVIDER OR SUPPLIER KINGSTON CARE CENTER OF FORT WAYNE				STREET ADDRESS, CITY, STATE, ZIP CODE 1010 W WASHINGTON CENTER RD FORT WAYNE, IN 46825			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>capacity of 125 and had a census of 120 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where the residents have customary access were sprinklered. The facility had a detached unsprinklered storage building used for the storage of mowing equipment.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 10/01/12.</p>			K 000			